



# Lenexa Fire Department



## Fire Protection and Utility Equipment Identification

Rooms, units, or spaces containing fire protection equipment and utility controls must be properly identified. Proper identification includes two-inch (2") letters of a contrasting color to the background. Exceptions to this requirement will be granted by the fire code official when identification signs are part of a sign package used throughout a building. The following locations shall be identified:

- Electrical Room
- Sprinkler/Riser Room
- Alarm Panel
- Boiler Room
- Mechanical Room
- Alternative Fire Protection Controls
- Roof Access
- Interior/Exterior Pedestrian Door Blocked
- Elevator Room

Exterior overhead doors and their function shall not be eliminated without prior approval. Exterior overhead doors that have been rendered non-functional and that retain a functional door exterior appearance shall have a sign affixed to the exterior side of the door with the words DOOR BLOCKED. The sign shall consist of letters having a principal stroke of not less than 3/4 inch wide and not less than 6 inches high on a contrasting background.

LFD reserves the right to modify or amend the rules and procedures provided herein at any time.

Effective: April 1, 2019

Refers to: 2018 IFC 509.1

Approved by: 